

Wendy Danielson

From: Curt Moore
Sent: Wednesday, January 26, 2011 2:55 PM
To: Wendy Danielson
Subject: FW: The Resort at Teton Links

From: Bret Campbell [<mailto:bcampbell@tetoncountyfire.com>]
Sent: Wednesday, January 26, 2011 11:20 AM
To: Curt Moore
Subject: The Resort at Teton Links

Curt,

I have received and reviewed the CUP application packet for The Resort at Teton Links. Thank you for providing the information at an appropriate time for our review.

As you know, our agency approval would be granted upon the basis of an acceptable fire protection plan. Generally speaking, the plan must provide for "address, access, and water supply". The requirements are based upon the 2009 International Fire Code (IFC). I do not have concerns with the layout of the site plan; fire engines, ambulances, and RV have similar access requirements. An acceptable firefighting water supply will be required. And I am be happy to meet with the applicant and discuss the fire protection plan.

Thank you,

Bret Campbell
Assistant Chief



Teton County Fire Protection District
PO Box 474
625 North Airport Road
Driggs, ID 83422

Phone: 208-354-2760
Fax: 208-354-2764

_____ Information from ESET NOD32 Antivirus, version of virus signature database 5821 (20110126)

The message was checked by ESET NOD32 Antivirus.

<http://www.eset.com>