


TETON COUNTY FIRE PROTECTION DISTRICT  
PO Box 474 • 911 North Hwy. 33  
Driggs, Idaho 83422 • (208) 715-5201



---

November P&Z Hearing.

Dorothy Gale Seven Lot Subdivision Preliminary Plat.  
Is approved for fire department access and the proposed fire pond.

Hunnidale Two Lot Subdivision Concept.  
Is approved for fire department access, A water source is not required for a two-lot subdivision.

Tod Lea Six Lot Subdivision Preliminary Plat.  
Is approved for fire department access and the proposed fire pond water source for fire suppression.  
Hydrant location and turn around shall be reviewed on site with further details on the fill site.

Trestles Sixty-Eight Lot Subdivision Preliminary Plat.  
Is approved for fire department access and the three proposed water systems for fire suppression

**Wildflower Rural Reserve 26 Lot Subdivision PUD Preliminary Plat.**  
**Is approved for fire department access and under review for the water source for fire suppression.**

Thank you,

Earle Giles III  
Fire Marshal

[egiles@tetoncountyfire.com](mailto:egiles@tetoncountyfire.com)

(208) 715-5201