

7/22/2020

Corinne McAndrews  
P.O. Box 1065, Driggs, ID

Dear Corinne:

A speculative evaluation was conducted on March 5, 2020 on parcel RP05N46E293000 to determine if it could support an individual, basic sewage disposal system in accordance with Idaho Code IDAPA 58.01.03 and the Technical Guidance Manual for Individual and Subsurface Sewage Disposal. Based on your proposed location and size of project, this should be feasible with no special engineering required.

The speculative evaluation included having a 10-foot test hole dug on the above parcel. At that time no groundwater was observed and a monitoring well installed. I visited the same parcel on July 13, 2020 and observed again no water in the monitoring well which was at about 9 feet deep.

Based on the soil type, 300 feet would be required from any permanent surface water (>6 weeks of the year) to a septic drain field.

It is my understanding you will be working on a septic permit application to submit to our department. I anticipate being able to issue a septic permit meeting all required setbacks for a basic system.

Sincerely,



Eric Baird, REHS  
Eastern Idaho Public Health